

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

Sample Pt. Description:	WELL NO 3	Sample ID:	B2102099-001
Sample Pt ID:	7BEY	Sample Type:	Routine
PWS ID:	LA1015016	Sample Collector:	Austin
Water System Name:	TOWN OF PLAIN DEALING WATER SYSTEM	Collection date:	4/29/2021 10:30:00AM
Facility ID:	1015016-003	Lab Submittal date:	5/4/2021 11:40:00AM
Collection Address:			

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Inorganic Anions (300.0)					
Fluoride	2.4	mg/L	0.1	4.0	> 1/2 MCL

Sample Pt. Description:	WELL NO 2	Sample ID:	B2102099-002
Sample Pt ID:	7BEX	Sample Type:	Routine
PWS ID:	LA1015016	Sample Collector:	Austin
Water System Name:	TOWN OF PLAIN DEALING WATER SYSTEM	Collection date:	4/29/2021 10:40:00AM
Facility ID:	1015016-002	Lab Submittal date:	5/4/2021 11:40:00AM
Collection Address:			

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Inorganic Anions (300.0)					
Fluoride	2.4	mg/L	0.1	4.0	> 1/2 MCL

Sample Pt. Description:	WELL NO 4	Sample ID:	B2102099-003
Sample Pt ID:	7BTO	Sample Type:	Routine
PWS ID:	LA1015016	Sample Collector:	Austin
Water System Name:	TOWN OF PLAIN DEALING WATER SYSTEM	Collection date:	4/29/2021 10:15:00AM
Facility ID:	1015016-004	Lab Submittal date:	5/4/2021 11:40:00AM
Collection Address:			

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Inorganic Anions (300.0)					
Fluoride	2.2	mg/L	0.1	4.0	> 1/2 MCL

Qualifier Key

Qualifier	Description
> 1/2 MCL	Final Result > 1/2 MCL but < MCL

REVIEWED

Reviewed by: Aaron Hawkins

MAY 06 2021
 CM
 ENGINEERING SERVICES

John Bel Edwards
GOVERNOR

Dr. Courtney N. Phillips
SECRETARY

State of Louisiana
Louisiana Department of Health

5/6/2021

To: PWSID: LA1015016
TOWN OF PLAIN DEALING WATER SYSTEM

PLAIN DEALING LA 71064

Re: Chemical Analysis Conducted at the OPH Baton Rouge Laboratory

This letter is to acknowledge that the Louisiana Office of Public Health (OPH) – Engineering Services has received and reviewed the attached drinking water monitoring results. Water samples were collected from the above supply system by Regional OPH staff and were submitted to the Office of Public Health Chemistry Laboratory for analysis.

Please review and retain the enclosed results for your water system. Results that were less than the Laboratory's Minimum Detection Limit (MDL) are indicated by either the text "less than" or a value of zero. A result less than the Laboratory's MDL equates to a Non-Detection. Under 40 CFR §141.33 records of chemical analysis must be retained for a minimum of 10 years.

Sampling Summary

Date of Sampling : 4/29/2021

Facility : 1015016-003 WELL #3 DOTSON HILL N OF GST

Sample ID: B2102099-001

Sample ID: B2102099-002

Sample ID: B2102099-003

Flagged Sample(s)

Sample ID	Flagged Analyte	Flagged Reason	Follow Up Action (if necessary)
B2102099-001	FLUORIDE	> 1/2 MCL	Continue Otrly Sampling at Well
B2102099-002	FLUORIDE	> 1/2 MCL	Continue Otrly Sampling at Well
B2102099-003	FLUORIDE	> 1/2 MCL	Continue Otrly Sampling at Well